

ADA Deficiency Summary
City of Ypsilanti Parks and Recreation Master Plan

ADA Deficiency Summary
Accessible Approach/Entrance

	Candy Cane Park	Penninsular Park	Frog Island Park	Riverside Park	Waterworks Park	Prospect Park	Recreation Park	Parkridge Park	Parkridge Community Center	Rutherford Pool	Senior Center	Edith Hefley Tot Lot	Carrie Mattingly Tot Lot	Charles St. Tot Lot
Route of Travel														
Is there a route of travel that does not require the use of stairs?		■												
Is the route of travel stable, firm and slip resistant?	■	■			■	■	■	■					■	■
Is the route at least 36 inches wide?		■											■	
Can all objects protruding into the circulation path be detected by a person with a visual disability using a cane? <i>Note: In order to be detected using a cane, an object must be within 27 inches of the ground. Objects hanging or mounted overhead must be higher than 60 inches to provide clear head room. It is not necessary to remove objects that protrude less than 4 inches from the wall.</i>													■	
Do curbs on the route have curb cuts at drives, parking and drop-offs?					■				■					
Ramps														
Are the slopes of ramps no greater than 1:12? <i>Note: 1:12 = for every 12 inches along the base of the ramp, the height increases one inch.</i>		■	■					■	■					
Do all ramps longer than 6 feet have railings on both sides?		■	■					■						
Are railings sturdy, and between 34 and 38 inches high?														
Is the width between railings and curbs at least 36 inches?														
Are ramps non-slip?														
Is there a 5-foot long level landing at every 30 foot horizontal length of ramp, at the top and bottom of ramps and at switchbacks?														
Does the ramp rise no more than 30 inches between landings?			■					■						

ADA Deficiency Summary
City of Ypsilanti Parks and Recreation Master Plan