

Fire Safety inspection for tents: See NFPA 1 chap. 25. and NFPA 101 Chap. 11.11

- Covers no more than 75% of the premises, unless permitted by AHJ.
- NFPA 701 label, or other certificate.
- Minimum 10 feet between stake lines.
- Minimum 10 feet clearance around the tent from other combustible or vegetation.
- Minimum one portable fire extinguisher.
- Egress: No guy wire or rope crossing egresses. Provide a 7 foot head room.
- See 25.1.5 if combustibles are in the tent.
- Electrical system isolated from the public by proper elevation or guarding, and all electrical fuses and switches needs to be enclosed.
- Heating devices; see 25.1.10
- Generator; see 25.1.12
- Cooking equipment; see chapter 50.